

GOVERNMENT OF ASSAM
OFFICE OF THE ASSTT. EXECUTIVE ENGINEER (PHE) GOSSAIGAON SUB DIVISION
GOSSAIGAON

NO. APHEE/GOS/WR-01(Pt-II)/Lab/2019-20/09

Dated 19-08-2019

To,

✓ The Managing Director
Bodoland Public School
No. 2 Gossaigaon


Sub: - Submission of safe drinking water and sanitary condition certificate &
test report of drinking water quality

Ref: - No. BPS/03/2019/019 Dated 14th August / 2019

Sir,

With reference to the subject cited above, I am to submit herewith the proforma of safe drinking water and sanitary condition certificate duly filled & test report of drinking water sample, submitted on 14th August/2019 for favour of your kind information and necessary action.

Yours faithfully



Asstt. Executive Engineer (PHE)
Gossaigaon Sub Division
Gossaigaon

Memo No. APHEE/GOS/WR-01(Pt-II)/Lab/2019-20/

Dated

Copy to :-

1. The Executive Engineer (PHE), Gossaigaon Division for favour of kind information.


Asstt. Executive Engineer (PHE)
Gossaigaon Sub Division
Gossaigaon


APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Mr. Prabir Kr. Adhikary, Asstt. Executive Engineer (PHE)**, from Gossaigaon Sub Division from PHED, Gossaigaon inspected the **Bodoland Public School (BPS)**, No.2 Gossaigaon, Kokrajhar, BTAD, Assam-783360 on **17-08-2019 at 1.51 PM** and found that the Bodoland Public School (BPS) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of **02 (Two) Years**.

Signature with Seal :


Asstt. Executive Engineer (PHE)
Gossaigaon Sub-Division
Gossaigaon

Name

: Mr. Prabir Kr. Adhikary

Designation

: Asstt. Executive Engineer (PHE)

To,

Managing Director,
Bodoland Public School (BPS)
No. 2 Gossaigaon, Kokrajhar
BTAD, Assam-783360

RESULT OF TESTING AND ANALYSIS FOR PHYSICAL & CHEMICAL CONTAMINATOIN


NAME OF DISTRICT : KOKRAJHAR


NAME OF DIVISION : GOSSAIGAON PHE DIVISION


**NAME OF LABORATORY : SUB DIVISIONAL LEVEL LABORATORY (SDLL)
GOSSAIGAON PHE SUB DIVISION ,GOSSAIGAON.**

SL NO	DATE OF TESTING	TYPE OF SOURCE	TEST PARAMETER	DESIRABLE LIMIT (mg/l)	PERMISSIBLE LIMIT (mg/l)	RESULT	REMARKS
1	2	3	4	5	6	7	8
1	17-Aug-2019	HTW: Bodoland Public School, No. 2 Gossaigaon	Ph_Value	6.50	8.50	6.50	Water is safe for drinking. But periodic checking of water is needed.
			Turbidity	5 NTU	2.00	
			Iron	0	1.00	0.21	
			Manganese	0.10	0.30	0.09	
			Residual Chlorine	0.20	1.00	0.15	
			Nitrate	0	45	3.28	
			Fluoride	1.00	1.50	0.34	
			Bacteriological	Not found	

Countersigned


**Asstt. Executive Engineer (PHE)
Gossaigaon Sub Division
Gossaigaon**


**Junior Engineer (PHE)
i/c. Sub Divisional Level Laboratory
Gossaigaon**


**Asstt. Chemist (SDLL)
Gossaigaon Sub Division (PHE)
Gossaigaon**